



Guadalupe County Fire Marshal Office

Patrick Pinder, Fire Marshal

101 E. Court Street, Suite 208

Seguin, Texas 78155

(830) 303-8856



MOBILE FOOD VENDORS CHECKLIST

Mobile food vendors conducting business within the unincorporated areas of Guadalupe County must have their food trucks and/or trailers registered and permitted on an annual basis with the County. The following constitutes a mobile food vendor:

- A registered and/or licensed vehicle
- A registered and/or licensed trailer
- Any mobile structure on wheels

The following is a checklist of information that should be used as an aid and is not intended to cover every requirement:

___ Registered and inspected by the Guadalupe County Fire Marshal's Office on an annual basis.

___ Permit Application with \$200.00 fee payable to Guadalupe County

___ Current State license plate tag

___ Current Inspection tag

___ Minimum of one 2A10BC fire extinguisher within truck or trailer. The fire extinguisher must be:

___ easily accessible at all times

___ serviced and tagged annually by a licensed company

___ A "Class K" fire extinguisher, if a deep fryer is in use. The fire extinguisher must be:

___ easily accessible at all times

___ serviced and tagged annually by a licensed company

___ Electrical wiring inside truck/trailer must be in conduit

___ No exposed or spliced wire

___ Wiring and/or cords used for outdoor lighting must be rated for outdoor use

___ No exposed or spliced wire

___ Must not be subject to damage by vehicle traffic

___ All electrical outlets, switches, and junction boxes must have cover plates

___ Any light fixtures within the truck or trailer must have their protective covers in place

___ Propane tanks must be secured properly with a chain or strap



Guadalupe County Fire Marshal Office

Patrick Pinder, Fire Marshal

101 E. Court Street, Suite 208

Seguin, Texas 78155

(830) 303-8856



MOBILE FOOD VENDORS CHECKLIST CONTINUED

- ___ Propane supply hoses must be stainless steel/metal
- ___ "No Smoking" signs must be posted at or near propane tanks
- ___ Vent Hood must be free of excessive grease build-up
- ___ No flammable liquids shall be stored inside the truck or trailer